



- ① NEW UTILITY (SEE DETAIL #409 FOR SEPARATION REQUIREMENTS).
- ② BANDED RUBBER COUPLING WITH STAINLESS STEEL SHEAR BANDS.
- ③ INITIAL BACKFILL. (SEE DETAIL #110).
- ④ UNDISTURBED SOIL.
- ⑤ EXISTING SEWER SERVICE OR MAIN.
- ⑥ ABS PIPE.
- ⑦ SELECT BACKFILL. (SEE DETAIL #110).
- ⑧ FINISH BACKFILL. (SEE DETAIL #110).
- ⑨ EXISTING STRUCTURAL SECTION.
- ⑩ THREE (3) INCHES MIN. OF ASPHALT CONCRETE PAVING OR MATCH EXISTING.

NOTE:

- A. GAP BETWEEN THE EXISTING AND NEW PIPE AT COUPLINGS SHALL NOT EXCEED ONE QUARTER INCH (1/4").
- B. IF ① IS A WATER PIPE, THAN ⑥ SHALL BE CAST IRON OR DUCTILE IRON PIPE FOR 10' EACH SIDE OF THE WATER PIPE.

THE CITY OF WEST SACRAMENTO – STANDARD DETAIL

APPROVED BY:  CITY ENGINEER
 C-38733 P.E. NO. 3/31/05 DATE

TITLE:

SEWER REPAIR

REVISION:

REVISION:

REVISION:

REVISION:

STANDARD
DETAIL #: 403

